

## Night Check Personnel:

The security system for the Sloan Clubhouse has recently been repaired and upgraded. The repairs included replacing two security touch pads, like most of us have in our homes, as well as upgrading several of the six motion sensors in multiple locations in the Clubhouse. The security touch pads are located in the vestibule inside the main entrance and the vestibule on the lower level to the indoor and outdoor pools.

Now that the security system is more functional, we can use it as a supplementary check to ensure the Clubhouse is secure -- but only if you desire to do so. The two Honeywell touch pads monitor 16 zones that when activated will inform you if a certain door is open or if someone or something is moving in one of the six areas the motion detectors are monitoring. The touch pads will indicate if a door is open with a text description on the pad (1: Front Door, 2: Indoor/Outdoor Pool Second & Third Double-Door Sets, 10: Lower Level Door to Vestibule, 11: Club Room Door to Deck, 12: Kitchen Door, 13: Library Doors, 14: Weight Room Door, 15: Exercise Room Door, 16: First Indoor/Outdoor Pool Double-Door Set) and the six areas the motions sensors monitor, again with a text description: (3: Billiard Room, 4: Club Room, 5: Weight Room, 6: Upper Hall, 7: Lower Hall, 8: Indoor Pool).

**When you perform Night Check you still need to conduct a thorough inspection of the Sloan Clubhouse as specified on the checklist.** The security system does not monitor the windows, the stove, refrigerator and other items nor will it tell if someone or something is in the building unless it is moving in one of the areas the system monitors. Also, note that the Security System Keypad is located below the Fire System Keypad in the Front Vestibule.

**There is no need to use the security system for Night Check.** However, if you chose to use the security system as a supplementary check before leaving the Clubhouse, the following information is provided. When looking at the keypad, if the keypad shows "Ready" (Green Light) then the doors are closed and there is no movement in the 6 areas the motion sensors monitor. If the system shows "Not Ready" (No Green Light) the system should inform you with a text message about the zone that has a problem -- a door is open or there is motion in one of the monitored areas.

**Caution: Do not press the Police, Fire or medical buttons since they will activate a response from those departments.**

A copy of this note will be placed in the red Night Check binder in the clubhouse.