



NOTE:
 1. CONTRACTOR TO PROVIDE A MINIMUM OF 1.5' OF CLEARANCE WHERE WATERMAIN CROSSES PROPOSED SANITARY SEWER AND SANITARY SEWER CROSSES PROPOSED WATERMAIN.
 2. CONTRACTOR TO PROVIDE A MINIMUM OF THREE (3) INCHES OF CLEARANCE BETWEEN STORM SEWER PIPE AND SANITARY SEWER SERVICE LATERALS, DEEP CUT LATERALS AND LATERAL INSETS TO BE USED WHERE NECESSARY.

SCALE:
 1" = 50' HORIZ.
 1" = 5' VERT.

EASEMENT PROFILES
REGENCY AT PROVIDENCE
 (1. FOGEL TRACT)
 TWP., MONTGOMERY CO., PENNSYLVANIA

REV.	DATE	DESCRIPTION	DRAWN
5	1/31/05	FINAL CONSTRUCTION DRAWINGS	MDD
4	11/22/04	REVIEW LETTER 9/28/04; RDS, A, B, D COMM CTR	MDD
3	8/04/04	AGENCY REVIEW LETTER DATED 7/29/04	MDD
2	7/21/04	AGENCY REVIEW LETTERS 6/29/2004, 6/30/2004	MDD
1	6/07/04	AGENCY REVIEW LETTERS; TOWNSHIP COMMENTS	PAB

ESE EASTERN STATES ENGINEERING
 CIVIL ENGINEERS - LAND SURVEYORS - LANDSCAPE ARCHITECTS - LAND PLANNERS

250 GIBRALTAR ROAD
 SUITE 2E
 HORSHAM, PA 19044
 TEL: (215) 914-2050
 FAX: (215) 293-5488

JAMES D. TAKACS
 REGISTERED PROFESSIONAL ENGINEER
 No. PE055040
 PENNSYLVANIA

James Takacs

DATE:	12/9/03	SCALE:	AS NOTED
DESIGN:	JT	DRAWN:	PAB
JOB NO.:	1114	FILE NAME:	S-PROP-ESE
REV.:	SD07.19		
SHEET:	38	OF:	78